



EASLEY COMBINED UTILITIES

A Community Tradition

Easley Combined Utilities

Conversion Cost from Overhead Electric Service to Underground Electric Service

Adopted by the Commission of Easley Combined Utilities

January 22, 2019

1. 4/0 or 2/0 Underground Service

Minimum Charge: \$1,000. Includes 200 feet of wire.

2. 350 MCM Underground Service

Minimum Charge: \$1,200. Includes 200 feet of wire.

3. Installation Cost for Underground Rental Lights

All underground conductor installed to serve a rental light be installed at a cost of \$15 per foot.

4. Underground Bore Charge: \$500

General:

Surface must be within 6 inches of final grade prior to installation of underground electric facilities or bore.

Underground secondary shall not be installed at a length greater than 200 feet. If installation length is greater than 200 feet, primary conductor, transformer, and secondary will be installed at the customer's expense. Exceptions can be made by the Electrical Superintendent at his discretion.