



EASLEY COMBINED UTILITIES

A Community Tradition

Temporary Electric Service

Temporary single-phase service, 120/240 volts, may be furnished for construction purposes relating to establishing permanent service in accordance with the following:

- A. The customer requesting temporary service must first establish an account with Easley Combined Utilities by completing a Residential Service Application or Commercial Service Application. If an account is already established, a temporary service fee is charged and payment must be made prior to connection.
- B. The customer must provide a suitable pole and approved meter loop installed at a location agreed upon by the customer and ECU.
- C. Temporary service must be located at a site convenient to existing facilities, or the cost to install and remove facilities may be charged.
- D. Temporary service must be inspected by ECU prior to connection.

Specification Drawings

Temporary Loads With Underground Service

Temporary Loads With Overhead or Underground Service